

GOVERNMENT OF TELANGANA  
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION  
Directorate of I.P.M,P.H.Labs, Food (H) Administration, Narayanaguda.

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1. Sample From:

Pallavi School, Sy.No: 72/E/2, 77, 73/EE/2, 71/A, 79/AA/A, 79/A, Mallampet Village, Dundigal, Gandimaisamma (M), Medchal Dist .
2. Collected by:

Mr. Harish
3. Collected on :

11-04-2025

4.Received on: 15-04-2024

Lab. Ref. No.	Source	Exact location	Residual Chlorine mg per liter	Total coliform bacteria (MPN Index) per 100ml	Faecal coliform bacteria per 100ml	Esch. coli per 100ml
6717	R.O water	Direct R.O water	...	Nil	....	....
6718	R.O water (TPC)	Direct R.O water	Total Aerobic Bacterial Plate Count for 24 hrs at 37 <sup>0</sup> c = 5 CFU / ml			

Remarks: The above samples are bacteriologically satisfactory .



Dy.Chief Water Analyst